






THESE DRAWINGS ARE PRELIMINARY AND ARE NOT TO BE USED FOR CONSTRUCTION. ANY CHANGES TO BE MADE TO THESE DRAWINGS MUST BE MADE BY THE ARCHITECT. THE USER OF THESE DRAWINGS SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR OBTAINING THE SERVICES OF A LICENSED ELECTRICAL ENGINEER FOR THE DESIGN AND INSTALLATION OF THE ELECTRICAL SYSTEM. THE ARCHITECT SHALL NOT BE RESPONSIBLE FOR THE DESIGN OR INSTALLATION OF THE ELECTRICAL SYSTEM.



ELECTRICAL SYMBOLS	
NOTE: ALL SYMBOLS MAY NOT BE USED	
DOTTED SYMBOLS INDICATE EXISTING FIXTURE, EQUIPMENT, ETC.	
SYMBOL	EXPLANATION
—	BRANCH CIRCUIT CONCEALED IN CEILING OR WALL
---	BRANCH CIRCUIT CONCEALED IN GROUND OR FLOOR
(XX-XX)	BRANCH CIRCUIT HOMERUNS TO PANEL
■	"NL" FIXTURE SHALL BE UNSWITCHED
■	SURFACE MNT. LIGHTING AND POWER PANELBOARD
■	RECESS. MNT. LIGHTING AND POWER PANELBOARD
Ⓢ	MECHANICAL EQUIPMENT SYMBOL
②	KEYED NOTE REFERENCE
ⓧ	JUNCTION BOX
Ⓢ	DUPLEX RECEPTACLE OUTLET
Ⓢ	QUAD RECEPTACLE OUTLET
WP GFCI	DUPLEX RECEPTACLE WEATHERPROOF AND GFCI
Ⓢ	DISCONNECT SWITCH
◇	SURFACE MOUNTED FIXTURE
Ⓢ	WALL MOUNTED EXIT LIGHT (SINGLE FACE)
○	PENDANT MOUNTED FIXTURE
□	RECESSED FIXTURE
■	"NL" FIXTURE SHALL BE UNSWITCHED
○	WALL MOUNTED FIXTURE
S	SINGLE POLE SWITCH
Ⓢ	EXHAUST FAN
Ⓢ	NETWORK AND VOICE OUTLET
Ⓢ	FIRE ALARM HORN
Ⓢ	FIRE ALARM HORN/STROBE
Ⓢ	FIRE ALARM STROBE
Ⓢ	DUCT SMOKE DETECTOR
Ⓢ	FEEDER TAG
Ⓢ	EMERGENCY LIGHTING UNIT
F1	FIXTURE TYPE SYMBOL



NOTE: BLANDING CITY POWER TO MAKE ALL CONNECTIONS AT EXISTING TRANSFORMER. ELECTRICAL CONTRACTOR SHALL PROVIDE TRENCHING, BACK FILL, PATCHING TO MATCH HARDSCAPE AND SOFTSCAPE. INCLUDE IN BID - COST OF WORK AND EQUIPMENT SUPPLIED BY BLANDING CITY POWER. (ESTIMATE \$1500.00) IF ACTUAL FEES ARE LESS THAN THIS AMOUNT, ELECTRICAL CONTRACTOR SHALL REIMBURSE THE DIFFERENCE TO THE OWNER BY CHANGE ORDER. FOR INFORMATION CONTACT BLANDING CITY POWER AT 1-435-678-2791.



POWER RISER DIAGRAM
SCALE: NONE

VERIFY ALL FIXTURES, FINISHES, AND LAMP TYPES WITH OWNER BEFORE ORDERING LIGHT FIXTURES.

FIXTURE SCHEDULE						
SYMBOL	MANUFACTURER		FIXTURE VA	LAMP TYPE	MOUNTING	REMARKS
	NAME	CATALOG NUMBER				
F1	AC LIGHTING DESIGN	#3001	100	1-100W A19	WALL	WET LOCATION INCANDESCENT VERIFY STYLE & FINISH WITH ARCHITECT
F2	AC LIGHTING DESIGN	#10	100	1-100W A19	WALL	INCANDESCENT VERIFY STYLE & FINISH WITH ARCHITECT
F3	AC LIGHTING DESIGN	#83	100	1-100W A19	PENDANT	INCANDESCENT VERIFY STYLE & FINISH WITH ARCHITECT
F4	AC LIGHTING DESIGN	#40	100	1-100W A19	WALL ABOVE MIRROR	INCANDESCENT VERIFY STYLE & FINISH WITH ARCHITECT
F5	LITHONIA PORTFOLIO PRESCOLITE OMEGA LIGHTOLIER	AFV 26DTT BAR GEB C7042-E-7451-LI (TRIPLE) CFR626EB-ST372A OMEGA2H26GPI-CS 1102126U-1113TCL	33	1-F26-DTT	RECESSED	ELECTRONIC BALLAST
F6	ALERA	CVL3TB-40/60-FOM/LD/EB8/120V/MW	100	3-F32T8/SP35	AIRCRAFT CABLE	ELECTRONIC BALLAST CABLE LENGTH BY ARCHITECT
F7	LITHONIA PORTFOLIO PRESCOLITE OMEGA LIGHTOLIER	AFV 42TRT BAR GEB C7042-E-7451-LI (TRIPLE) CFR626EB-STF802 OMEGA2H26GPI-CS 7142BU-8022CCLW	48	1-F42-TRT	RECESSED	ELECTRONIC BALLAST
Ⓢ	LITHONIA HUBBELL MCPHILBEN LIGHTGUARD	ELM2 PEG-12-2R61 CAS VP6N50W	5.4		WALL	
Ⓢ	LITHONIA HUBBELL MCPHILBEN LIGHTGUARD	LQM S W 1 G 120 EL N PWP6WL9 CVL-1-LQW-EM ULNIG-W	4	LED	UNIVERSAL	NICKEL/CADIUM BATTERY

EQUIPMENT SCHEDULE											
SYMBOL	DESCRIPTION	QNTY. UNITS	VOLTS	PHASE	BRKR	DISC.	FUSE	FEEDER	STARTER	HP OR VA	FLA (MCA)
Ⓢ	ELECTRIC HEATER	1	120	1	20A	TOGGLE SWITCH	---	#12	---	1500 VA	
Ⓢ	EXHAUST FAN	1	120	1	20A	PLUG	---	#12	---	60W	
Ⓢ	ROOF TOP UNIT	1	240	1	60A	60A	---	#6	---		52.3 MCA
Ⓢ	ROOF TOP UNIT	1	240	1	60A	60A	---	#6	---		52.3 MCA

NOTE: VERIFY ALL EQUIPMENT LOCATIONS, QUANTITIES, AND CONNECTION REQUIREMENTS (I.e. VOLTAGE, PHASE, FLA, ETC.) WITH MECHANICAL DRAWINGS/SUBMITTALS BEFORE BEGINNING ROUGH IN.

MAXIMUM VALUES INDICATED. FINAL BREAKER/FUSE & DISCONNECT SIZE SHALL BE DETERMINED BY MANUFACTURER'S RECOMMENDATION FOR ACTUAL EQUIPMENT INSTALLED.

PANEL SCHEDULE																						
PANEL: "S"			BUS AMPS: 400						USE													
VOLTAGE: 240 / 120			PHASE: 1			MAIN OVERCURRENT DEVICE: NONE						E = Equipment Load										
MOUNTING: SURFACE			WIRE: 3			MAIN OVERCURRENT AMPS: NA						L = Lighting Load										
ENCLOSURE: NEMA 1									MINIMUM EQUIPMENT RATING: 22,000 AMPS (RMS-SYM)							R = Receptacle Load						
REMARKS:																						
No.	BREAKER	TRIP AMPS	POLE	CIRCUIT NAME	FEEDER		CKT. LOAD	LOAD (WATTS/VA)		CKT. LOAD	FEEDER		CIRCUIT NAME	BREAKER		No.						
					C	WIRE GRD		USE	WATTS		ØA	ØB		WATTS	USE		GRD	WIRE	POLE	TRIP AMPS		
1	20	1	TIMECLOCKS	3/4"	#12	#12	E 540	6,816		6,276	E	#10	#6	1"	AC-1	2	60	2				
3	20	1	LIGHTING	3/4"	#12	---	L 900		7,176	6,276	E	#10	#6	---	---	---	20	4				
5	20	1	LIGHTING	3/4"	#12	---	L 1,360	7,636		6,276	E	#10	#6	1"	AC-2	2	60	6				
7	20	1	LIGHTING	3/4"	#12	---	L 1,200		7,476	6,276	E	#10	#6	---	---	---	20	8				
9	20	1	LIGHTING	3/4"	#12	---	L 1,524	1,524										10				
11	20	1	LIGHTING	3/4"	#12	---	L 1,652		1,652									12				
13	20	1	LIGHTING	3/4"	#12	---	L 1,200	2,700		1,500	E	#12	#12	3/4"	EH-1	1	20	14				
15									720	720	R	#12	#12	3/4"	RECEPTACLES	1	20	16				
17									360	360	R	#12	#12	3/4"	RECEPTACLES	1	20	18				
19									900	900	R	#12	#12	3/4"	RECEPTACLES	1	20	20				
21									720	720	R	#12	#12	3/4"	RECEPTACLES	1	20	22				
23									720	720	R	#12	#12	3/4"	RECEPTACLES	1	20	24				
25									720	720	R	#12	#12	3/4"	RECEPTACLES	1	20	26				
27									540	540	R	#12	#12	3/4"	RECEPTACLES	1	20	28				
29									540	540	R	#12	#12	3/4"	RECEPTACLES	1	20	30				
31																		32				
33																		34				
35	20	1	SPARE												SPARE	1	20	36				
37	20	1	SPARE												SPARE	1	20	38				
39	20	1	SPARE												SPARE	1	20	40				

ØA	ØB	LTG LCL (DEMAND)
4,084	3,752	1,959
2,340	2,880	5,220
14,592	12,552	27,144

TOTAL LOAD (VA) 21,016 19,184 42,159
TOTAL LOAD (AMPS) 175 160 176

NOTES:
1. ALL INSULATION ON CONDUCTORS TO BE THIN UNLESS NOTED OTHERWISE.
2. RECEPTACLE LOAD CALCULATED AS PER SECTION 220.13 OF THE NATIONAL ELECTRICAL CODE.

FEEDER SCHEDULE							
TYPE	COND. SIZE	CONDUCTORS QUAN.	COND. SIZE	GND. COND.	TYPE	COND. SIZE	GND. COND.
20	3/4"	2	#10	#10	32X	2"	3
30	3/4"	3	#10	#10	41X	2"	4
28	3/4"	2	#8	#10	42X	2"	4
38	3/4"	3	#8	#10	33X	2"	3
26	1"	2	#6	#10	43X	2"	4
34	1"	3	#4	#8	44X	2"	4
33	1 1/2"	3	#3	#8	325	2 1/2"	3
43	1 1/2"	4	#3	#8	335	3"	3
31	1 1/2"	3	#1	#6	340	3"	3
32	1 1/2"	3	#2	#6	350	3"	3
42	1 1/2"	4	#1	#6	425	3"	4
41	1 1/2"	4	#1	#6	435	3"	4
21X	1 1/2"	2	#1/0	#6	440	3" 1/2"	4
31X	2"	3	#1/0	#6	450	3 1/2"	4

NOTE: GROUND CONDUCTOR SIZE IS NOT APPLICABLE FOR PARALLEL PHASE CONDUCTORS.



ROYAL ENGINEERING
ELECTRICAL ENGINEERS
2250 W. CENTER SPRINGVILLE, UTAH 84063 801-489-5459

COPYRIGHT®
THESE DOCUMENTS ARE INSTRUMENTS OF PROFESSIONAL SERVICE AND THE INFORMATION CONTAINED HEREIN IS INCOMPLETE UNLESS IN CONJUNCTION WITH ROYAL ENGINEERING'S INTERPRETATIONS, DESIGNER'S OBSERVATIONS AND ADMINISTRATIONS. USE OR REPRODUCTION OF THESE DOCUMENTS IN WHOLE OR IN PART WITHOUT ROYAL ENGINEERING'S CONSENT IS IN VIOLATION OF COMMON LAW, COPYRIGHTS, STATUTORY AND OTHER RESERVED RIGHTS. REFER TO ACT 17 U.S.C. PAR. 811 (1991) WHICH PRESUMES STATE AND LOCAL PUBLIC RECORD ACTS. REFER TO ACT 17 U.S.C. PAR. 301 (1991).

ROYAL# J31208

ELECTRICAL SCHEDULES & DETAILS
SCALE: NONE

PJH ARCHITECTS
3366 HIDDEN HILLS DRIVE
P.O. BOX 2268
CEDAR CITY, UT 84720
(435) 865-9900
(435) 865-9927 FAX
www.pjhutah.com

E-601
February 3, 2004